

		PARAMETRII FIZICO-CHIMICI																		PARAMETRII BACTERIOLOGICI					
Data	Locul de prelevare	Amoniu	Nitriti	Oxidab	pH	Fier	Alum	Turbid	Cl2lib	Cl2lrg	Durit	Cloruri	Conduc la 25°	Azotati	Sulfati	Mangan	Activ alfa globala	Activ beta globala	Cul/ gust/ Miros	Clostrid. perfring	Entero	Ecoli	Bact. coli	NTG 22°C	NTG 37°C
		mg/l	mg/l	mgO ₂ /l	unit pH	mg/l	µg/l	NTU	mg/l	mg/l	°germ	mg/l	µS/cm	mg/l	mg/l	mg/l	Bq/l	Bq/l		UFC /100ml	UFC /100ml	UFC /100ml	UFC /100ml	UFC/ ml	UFC/ml
C.M.A cf Ordonanta nr.7/2023		0.5	0.5	5	6,5/9,5	0.2	200	4	0,1/0,5		≥5	250	2500	50	250	0.05	0.1	1	n.m.a		0	0	0	0	0
CONSUMATORI SFANTU GHEORGHE																									
12.08.	Parochia Catolica, Santionlunca nr.213	<0.020	<0.020	<0.50	7.64	<0.020		<0.41	0.2	0			694	18.27					n.m.a		0	0	0	<1	<1
18.08.	Centrul de Diagnostic MEDLIFE , str.Brazilor nr.10	<0.020	<0.020	<0.50	7.39	<0.020		<0.41	0.2	0	20.8	19.3	685	21.76					n.m.a		0	0	0	<1	<1
31.08.	Restaurant KOLCZA, str.Spitalului nr.30	<0.020	<0.020	<0.50	7.63	<0.020		<0.41	0.18	0	20.8	18.5	739	18.62	31.61	0.023			n.m.a		0	0	0	<1	<1
CONSUMATORI INTORSURA BUZAULUI																									
26.08.	Stroe Daniela, Ladauti, str.Principala nr.6	<0.020	<0.020		7.85	<0.020		<0.41	0.08	0.04			418	7.5					n.m.a		0	0	0	<1	<1
CONSUMATORI COVASNA																									
18.08.	Mate Zoltan, Chiurus, str.Kovasznai Peter nr.18	0.02	<0.020	0.5	7.45	<0.020	73.7	0.56	0.08	0	3.14	5.77	129	5.31					n.m.a	0	0	0	0	<1	<1
25.08.	Bazin Montana							0.86	0.1	0.02									n.m.a		0	0	0	<1	<1
	Bazin Cerat							0.7	0.31	0.04									n.m.a		0	0	0	<1	<1
	Bazin Brates							0.61	0.95	0.2									n.m.a		0	0	0	<1	<1
	Bazin Pachia							0.83	0	0									n.m.a		0	0	0	<1	<1
	Bazin Telechia							0.62	0.62	0.09									n.m.a		0	0	0	<1	<1
CONSUMATOR TARGU SECUIESC																									
03.08.	Sanzieni, Hidrant stradal nr.7	<0.020	<0.020	<0.50	6.95	0.062		0.68	0.09	0	22.13	14.1	731	<5.0	24.64	<0.01			n.m.a		0	0	0	60	70
24.08.	Sanzieni, str.Principala nr.187-Szasz Ludovic	<0.020	<0.020	<0.50	7.03	0.021		0.61	0.06	0	19.87		721	<5.0					n.m.a		0	0	10	42	34
02.09.	Sanzieni, str.Principala nr.187-Szasz Ludovic	<0.020	<0.020	<0.50	7.04	0.029		<0.41	0.06	0	20.22		779						n.m.a		0	0	0	<1	<1
CONSUMATOR VALEA CRISULUI																									
11.08.	Hidrant stradal, Calnic							0.68	0.05	0									n.m.a		0	1	25	71	63
CONSUMATOR BODOC																									
11.08.	Iesire statie, Bodoc	<0.020	<0.020	1.12	7.24	<0.020		0.72	0.08	0	15.1	32.4	702	<5.0	27.39	<0.015			n.m.a		0	0	0	<1	<1
CONSUMATOR GHIDFALAU																									
11.08.	Iesire statie Zoltan	0.081	<0.020	1.31	7.56	0.114		0.61	0.11	0	18.1	17.7	706	<5.0	22.72	<0.015			n.m.a		0	0	0	<1	<1
IESIRE STATIE CATALINA																									
25.08.	Iesire statie	0.37	<0.020	0.59	7.21	0.084		0.81	0.07	0.00	13.78		583	<5.0	30.23	0.025			n.m.a		0	0	0	<1	<1
CONSUMATOR SI REZERVOR GHELINTA																									
25.08.	Ghelinta, SC.TRYK SRL, str.Principala	<0.020	<0.020	<0.50	6.9	<0.020		<0.41	0.06	0	12.08		450	23.9					n.m.a		0	0	0	<1	<1
25.08.	Ghelinta , Rezervor 400 mc							<0.41	0.13	0									n.m.a		0	0	0	<1	<1

APROBAT

ÎNTOCMIT

Sef Compartiment SMI
ing.Szántó Susana



Şef Laborator Apa Potabila Sf.Gheorghe
ing.Ugon Noémi

